

***Del Oro Water Company - Arbuckle District  
2024 Emergency Pump Replacement***

**NOTICE  
IN ACCORDANCE WITH THE STANDARD PRACTICE U-36-W OF THE  
CALIFORNIA PUBLIC UTILITIES COMMISSION**

The Well No. 1 pump in the Arbuckle District has failed due to partial collapse of the well casing’s perforations. The video logs taken by the engineers have determined that, due to subsidence in the general area caused by over pumping, pressure caused by the ground settling has compromised the well casing. A submersible pump will replace the existing turbine pump at a cost of \$55,022 allowing Well No. 1 to continue operating before its eventual required replacement. The installation is to take place at approximately the end of January or first of February 2024. THERE WILL BE NO PLANNED INTERRUPTION OF SERVICE.

With our best estimate of the cost to complete this project, the total potential impact on rates are as follows:

**The rate impact is approximately \$10.50 per month for the average customer.**

Metered Rate:

<u>Per Meter</u>	<u>Current Per Month</u>	<u>Proposed Per Month</u>	<u>Proposed Monthly Increase</u>
For 1-inch meter	57.43	62.66	5.23
For 1 1/2 inch meter	96.23	105.00	8.77
For 2 inch meter	142.79	155.80	13.01

  

<u>All water, per 100 cu. Ft.</u>	<u>Current Per ccf</u>	<u>Proposed Per ccf</u>	<u>Proposed Increase per ccf</u>
	\$2.312	\$2.523	\$0.211

**Bill Comparison - 1" Service for all Customers**

<u>Monthly Usage (ccf)</u>	<u>Present Rates</u>	<u>Proposed Rates</u>	<u>\$ Increase</u>	<u>% Increase</u>
0	\$57.43	\$62.66	\$5.23	9.11%
10	80.55	87.89	7.34	9.11%
<b>25</b>	<b>115.23</b>	<b>125.73</b>	<b>10.50</b>	<b>9.11%</b>
40	149.91	163.57	13.66	9.11%
50	173.03	188.79	15.76	9.11%

Customers are also invited to comment in writing on this proposal. Comments must reference “Arbuckle Pump Replacement 2024”. Comments must be mailed within 20 days of the date of this notice (no later than January 24, 2024) and should be mailed to **Del Oro Water Co., Arbuckle District, Drawer 5172, Chico, CA 95927**, or be faxed to (530) 717-2639, or be emailed to [CommunityRelations@delorowater.com](mailto:CommunityRelations@delorowater.com).

Mailed: January 4, 2024